

KCCP LIMITED

(A Govt. of Kerala Undertaking)

"CLAY HOUSE", PAPPINISSERI PO. 670 561, KANNUR DT. KERALA

Telephone: 0497-2787671 & 2789633 Fax: 0497-2787281,

E-mail: keralaclays@gmail.com Website: www.kccpl.in

Ref: KCCP/TENDER/ 1336 /2026-27

Date: 03.08.2026

NOTICE INVITING E-TENDER

Tender ID: 2026_KCCPL_863915_1

Competitive e-tenders are invited through e-procurement from manufacturers / authorized dealers / distributors for the Supply, Installation, Testing, and Commissioning of a 25 kVA Silent Diesel Generator Set for company's Fuel Retail Outlet at Kanjikode, Palakkad District

Tender Fee	:	Rs.2,360/- (Including GST)
EMD	:	Rs.6,500/-
Pre-bid meeting	:	10.08.2026 at 12.00 PM
Tender closing date	:	17.08.2026 at 10.00 AM
Technical bid opening date	:	18.08.2026 at 04.00 PM

For details please visit www.etenders.kerala.gov.in

Sd/
MANAGING DIRECTOR

DETAILED SPECIFICATIONS

Sl No	Parameter / Component	Technical requirement
1	General Rating	Prime Power: 25 kVA / 20 kW, 3-Phase, 415 V, 50 Hz, 0.8 PF (lagging).
2	Acoustic Enclosure	Factory-fabricated Silent Enclosure conforming strictly to latest CPCB / MOEF sound emission norms. Made of CRCA sheet steel, pre-treated and powder-coated.

3	Diesel Engine	Heavy-duty, 3-cylinder, 4-stroke, 1500 RPM, water-cooled Diesel Engine (Conforming to ISO 3046 / BS 5514).
4	Alternator	As per standard
5	Fuel Tank & Base	Sub-base integrated fuel tank with minimum 8–12 hours continuous running capacity, equipped with level indicator, drain plug, and inlet/outlet connections.
6	Control Panel	AMF (Automatic Mains Failure) / Manual Control Panel with digital controller displaying Voltage, Current, kW, PF, Frequency, Operating Hours, Low Lube Oil Pressure, and High Coolant Temp. Includes MCCB/MCB of suitable rating.
7	Exhaust & Mounting	Residential/critical silencer with SS flexible exhaust bellow and anti-vibration mountings (AVM) between engine-alternator assembly and base frame.
8	Standards Compliance	Engine: ISO 3046 / IS 10000; Alternator: IS 4722 / BS 5000; Sound/Emissions: CPCB compliant.
	Warranty: The minimum warranty against defective material and poor workmanship should be 18 months from the date of dispatch or 12 months from the date of commissioning or 5000 hours of operation.	